



NOTE: The kickout flashing shall be min. 4" x 4" in. As required by IRC code R905.2.8.3 and be angled between 100° -110° to deflect water from dumping behind the siding and the end of the roof intersection.



EXTERIOR SIDE WALL MASONRY
 VENEER SUPPORT BY STEEL
 ANGLE WITH DRYFLEKT

DRAWN: AWL
 DATE: 6/14/16
 SCALE: NONE

DEALER/DISTRIBUTOR: GENERAL SHALE ENGINEERING
 DEPARTMENT

SPECIAL SHAPE
 JOB NO.
 EG16-002

DWG. NO.
 1 of 1